


Tested element: **SGG Stadip 64.1**

Sample surface area            S =        1,9 m<sup>2</sup>  
Volume of receiving room       V =        86 m<sup>3</sup>  
Volume of source room         98 m<sup>3</sup>

FREQ. Hz	R dB
100	27,8
125	28,6
160	32,1
200	29,0
250	30,4
315	31,5
400	32,6
500	35,3
630	35,9
800	35,6
1000	33,7
1250	32,4
1600	36,1
2000	38,6
2500	41,7
3150	44,2
4000	47,2
5000	49,0



Rating according to ISO 717-1 (in the band 100 ÷ 3150 Hz) based on laboratory measurements:

**R<sub>w</sub> (C; C<sub>tr</sub>) = 36 (-1 ; -2) dB**