


Tested element: **SGG Planilux 10 mm**

Sample surface area S = **1,9 m²**
Volume of receiving room V = **86 m³**
Volume of source room **98 m³**

FREQ. Hz	R dB
100	29,7
125	30,4
160	28,1
200	26,0
250	29,3
315	29,3
400	30,2
500	33,9
630	35,4
800	36,1
1000	34,5
1250	31,8
1600	31,3
2000	35,8
2500	38,7
3150	41,6
4000	45,0
5000	46,3



Rating according to ISO 717-1 (in the band 100 ÷ 3150 Hz) based on laboratory measurements:

R_w (C; C_{tr}) = 35 (-1 ; -2) dB