


Tested element: **SGG Planilux 8 mm**

Sample surface area            S =    1,9 m<sup>2</sup>  
Volume of receiving room       V =    86 m<sup>3</sup>  
Volume of source room         V =    98 m<sup>3</sup>

FREQ. Hz	R dB
100	26,1
125	24,7
160	27,4
200	25,7
250	25,6
315	27,9
400	29,1
500	31,9
630	33,7
800	35,2
1000	35,3
1250	32,6
1600	29,9
2000	31,4
2500	35,5
3150	38,8
4000	42,4
5000	43,6



Rating according to ISO 717-1 (in the band 100 ÷ 3150 Hz) based on laboratory measurements:

**R<sub>w</sub> (C; C<sub>tr</sub>) = 33 (-1 ; -2) dB**