


Tested element: **SGG Planilux 6 mm**

Sample surface area S = 1.9 m²
Volume of receiving room V = 86 m³
Volume of source room 98 m³

FREQ. Hz	R dB
100	20,8
125	19,9
160	24,4
200	24,0
250	26,1
315	27,6
400	28,4
500	30,8
630	32,4
800	33,9
1000	34,8
1250	35,4
1600	34,0
2000	28,0
2500	28,8
3150	32,4
4000	37,4
5000	38,9



Rating according to ISO 717-1 (in the band 100 ÷ 3150 Hz) based on laboratory measurements:

R_w (C; C_{tr}) = 32 (-1 ; -2) dB