


Tested element: SGG Planilux 8 (12) SGG Planilux 4 (12) SGG Planilux 4

Specimen surface
Receiving room volume
Source room volume

S = 1,88m²
V = 86m³
98m³

FREQ. Hz	R dB
100	23,6
125	21,8
160	21,6
200	20,6
250	25,4
315	26,1
400	28,2
500	32,3
630	36,2
800	39,2
1000	43,7
1250	45,9
1600	45,8
2000	46,0
2500	46,0
3150	40,1
4000	45,8
5000	48,5



R_w (C; C_{tr}) = 36 (-1 ; -5) dB

Rating according to ISO 717-1 (in the band 100 ÷ 3150 Hz) based on laboratory measurements: