


Tested element: SGG CLIMAPLUS 22-1SI (16Ar) 4

Specimen surface
Receiving room volume
Source room volume

S = 1,88m²
V = 86m³
98m³

FREQ. Hz	R dB
100	24,0
125	22,0
160	22,6
200	20,5
250	20,7
315	23,4
400	26,9
500	31,0
630	34,6
800	40,6
1000	46,6
1250	50,8
1600	52,3
2000	53,8
2500	51,0
3150	45,7
4000	50,7
5000	53,4

$R_w (C; C_{tr}) = 35 (-2 ; -5) \text{ dB}$



Rating according to ISO 717-1 (in the band 100 ÷ 3150 Hz) based on laboratory measurements: