


Tested element: SGG CLIMAPLUS 22-1SI (16 Ar) 6

Specimen surface
Receiving room volume
Source room volume

S = 1,88m²
V = 86m³
98m³

FREQ. Hz	R dB
100	24,4
125	23,0
160	22,6
200	21,3
250	23,1
315	27,0
400	29,5
500	34,1
630	37,8
800	43,2
1000	47,8
1250	50,3
1600	49,7
2000	46,4
2500	48,2
3150	50,7
4000	53,7
5000	55,8

$R_W (C; C_{tr}) = 37 (-1 ; -5) \text{ dB}$



Rating according to ISO 717-1 (in the band 100 ÷ 3150 Hz) based on laboratory measurements: