


Tested element: **SGG CLIMATOP 44-1SI (10 Ar) 4 (10 Ar) 4**

 Specimen surface
 Receiving room volume
 Source room volume

 S = 1,88m²
 V = 86m³
 98m³

FREQ. Hz	R dB
100	26,3
125	22,6
160	21,3
200	22,7
250	26,9
315	28,4
400	30,7
500	34,6
630	38,7
800	43,8
1000	49,4
1250	53,9
1600	55,4
2000	55,1
2500	51,9
3150	46,7
4000	53,2
5000	58,1

R_w (C;C_{tr}) = 38 (-1 ; -5) dB


Rating according to ISO 717-1 (in the band 100 ÷ 3150 Hz) based on laboratory measurements: